




SOUND ABSORPTION COEFFICIENT

Measured and evaluated according to ISO 354 and ISO 11654

Client:	Parafon
Surface:	PARAFON Exclusive D2 25 mm
Suspension Height:	w = 0

Octave band (Hz)	Sound absorption coefficient (-)
63	0
125	0.1
250	0.4
500	0.9
1000	0.95
2000	0.95
4000	1
α_w	0,70(MH)
NRC	0.80



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 16-051-M67	2016-03-09

