


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons		
Object:	ScreenIT A40 w. built in rail		
Size [mm]:	w = 2000	h = 650	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	0.5
250	0.9
500	1.2
1000	1.4
2000	1.6
4000	1.9
N₁₀ = 8.3	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 16-256-M2	2017-02-13

