




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	OFFECCT
Object:	Soundwave® Botanic BF 6 PCS.
Size [mm]:	w = 1755 h = 1170 d = 62

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.5
250	1.4
500	2.2
1000	2.3
2000	2.1
4000	2.1
N₁₀ = 4.8	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 13-99-R1	2013-09-03

