




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

| | |
|-------------------|------------------------------------|
| Client: | OFFECCT |
| Object: | Soundwave® Swell BF 6 PCS. |
| Size [mm]: | w = 1755 h = 1170 d = 80 |

| Octave band (Hz) | Equivalent sound absorption area / unit (m ² Sabine) |
|-----------------------------|---|
| 63 | 0.1 |
| 125 | 0.4 |
| 250 | 1.3 |
| 500 | 2.2 |
| 1000 | 2.3 |
| 2000 | 2.2 |
| 4000 | 2.1 |
| N₁₀ = 4.8 | |



| | |
|---------------------------------|---------------------|
| ORIGINAL TEST REPORT | DATE OF TEST |
| Akustikverkstan report 13-99-R1 | 2013-09-03 |

