




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Kinnarps		
<b>Object:</b>	Zonit 80		
<b>Size [mm]:</b>	w = 1200	h = 1900	d = 80

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.23
125	0.68
250	1.48
500	2.17
1000	2.17
2000	2.17
4000	1.82
<b>N<sub>10</sub> = 5.5</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
SP report P805772BE	2013-06-05

