




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons, Akustikmiljö / Am Acoustics		
Object:	Nivå 6 pcs		
Size [mm]:	w = 1800	h = 1200	d = 80

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	0.9
250	1.8
500	2.6
1000	2.7
2000	2.5
4000	2.6
N₁₀ = 4	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 16-239-M2	2016-11-25

