




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons, Akustikmiljö / Am Acoustics		
Object:	Lod		
Size [mm]:	w = 3000	h = 2400	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.4
125	1
250	2.4
500	4.1
1000	4.8
2000	4.6
4000	5.3
N₁₀ = 2.4	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 16-239-M23	2017-03-09

