




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Akustikmiljö / Am Acoustics		
Object:	Lätt		
Size [mm]:	w = 600	h = 1200	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.2
250	0.6
500	1.4
1000	1.3
2000	1.1
4000	1.1
N₁₀ = 9.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 16-239-M7	2017-03-09

