


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Akustikmiljö / Am Acoustics		
Object:	Lätt		
Size [mm]:	w = 900	h = 1200	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.3
250	0.9
500	1.8
1000	1.8
2000	1.6
4000	1.6
N₁₀ = 6.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 16-239-M9	2017-03-09

