




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Akustikmiljö / Am Acoustics		
<b>Object:</b>	Single		
<b>Size [mm]:</b>	w = 1500	h = 3000	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.4
125	1.2
250	2.6
500	4.1
1000	4.6
2000	4.4
4000	4.7
<b>N<sub>10</sub> = 2.4</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 16-239-M13	2016-12-14

