




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Akustikmiljö / Am Acoustics		
Object:	Single		
Size [mm]:	w = 1200	h = 1600	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.17
125	0.6
250	1.18
500	1.92
1000	2.17
2000	1.83
4000	1.86
N₁₀ = 5.5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 16-239-M5	2016-11-25

