




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Softline 30 Table		
<b>Size [mm]:</b>	w = 1600	h = 450	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.12
125	0.2
250	0.6
500	0.7
1000	0.8
2000	0.9
4000	1
N <sub>10</sub> = 14.3	



## ORIGINAL TEST REPORTS

Akustikverkstan report 17-094-M14  
Akustikverkstan report 17-094-M13

## DATE OF REPORT

2017-05-10  
2017-05-10

*The presented results are interpolated using the method described in ISO 20189 from the original test reports.*

