




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Softline 30 Table		
Size [mm]:	w = 1600	h = 450	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.12
125	0.2
250	0.6
500	0.7
1000	0.8
2000	0.9
4000	1
N₁₀ = 14.3	



ORIGINAL TEST REPORTS	DATE OF REPORT
Akustikverkstan report 17-094-M14	2017-05-10
Akustikverkstan report 17-094-M13	2017-05-10

The presented results are interpolated using the method described in ISO 20189 from the original test reports.

