




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Softline 30 Table		
Size [mm]:	w = 2000	h = 450	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.2
250	0.8
500	0.9
1000	1
2000	1.1
4000	1.2
N₁₀ = 11.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-094-M13	2017-05-10

