




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Softline 50 Table		
<b>Size [mm]:</b>	w = 1000	h = 650	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.2
125	0.3
250	0.6
500	0.9
1000	1.1
2000	1
4000	1.1
<b>N<sub>10</sub> = 11.1</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 15-065-M5	2015-04-10

