




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Softline 50 Table		
Size [mm]:	w = 1600	h = 650	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.2
125	0.4
250	0.9
500	1.4
1000	1.7
2000	1.7
4000	1.7
N₁₀ = 7.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 15-065-M6	2015-04-10

