




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Softline 50 Table		
<b>Size [mm]:</b>	w = 2000	h = 650	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.4
125	0.5
250	1.1
500	1.8
1000	2.2
2000	2.1
4000	2.2
<b>N<sub>10</sub> = 5.6</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 15-065-M7	2015-04-10

