




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Softline 50 Table		
Size [mm]:	w = 2000	h = 650	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.4
125	0.5
250	1.1
500	1.8
1000	2.2
2000	2.1
4000	2.2
N₁₀ = 5.6	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 15-065-M7	2015-04-10

