




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons		
Object:	ScreenIT A30		
Size [mm]:	w = 1600	h = 650	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.33
125	0.67
250	1
500	1.23
1000	1.37
2000	1.53
4000	1.63
N₁₀ = 8.1	



ORIGINAL TEST REPORT	DATE OF REPORT
SP report 4P03825	2014-06-08

