




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Götessons/ Gotessons		
<b>Object:</b>	ScreenIT A30		
<b>Size [mm]:</b>	w = 2000	h = 450	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.27
125	0.52
250	0.84
500	1
1000	1.1
2000	1.3
4000	1.4
N <sub>10</sub> = 10	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 2629-R4-M8	2023-03-22

