




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons		
Object:	ScreenIT A30		
Size [mm]:	w = 1000	h = 1400	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.2
125	0.42
250	1.1
500	1.5
1000	2
2000	2.3
4000	2.6
N₁₀ = 6.7	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 2629-R4-M14	2023-03-22

