




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Softline 30 Floor Screen		
Size [mm]:	w = 800	h = 1500	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	0.5
250	0.8
500	1.3
1000	1.7
2000	1.9
4000	2.2
N₁₀ = 7.7	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 15-240-M5	2016-01-29

