




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Scala Table		
Size [mm]:	w = 1800	h = 600	d = 60

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.2
250	0.7
500	1.1
1000	1.5
2000	1.7
4000	1.9
N₁₀ = 9.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan 17-094-M9	2017-05-19

