




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Stitch Table		
Size [mm]:	w = 860	h = 650	d = 85

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.3
250	0.7
500	0.9
1000	1
2000	1
4000	0.9
N₁₀ = 11.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan 17-094-M2	2017-05-19

