




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Stitch Table		
<b>Size [mm]:</b>	w = 860	h = 650	d = 85

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.3
250	0.7
500	0.9
1000	1
2000	1
4000	0.9
<b>N<sub>10</sub> = 11.1</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan 17-094-M2	2017-05-19

