




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

**Client:** Götessons/ Gotessons  
**Object:** HALF A HUT WITH FRONT SCREENS AND DOOR  
**Size [mm]:** w = 1880      h = 2270      d = 970

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	2.6
125	2.7
250	5.2
500	6.5
1000	7.2
2000	8
4000	9.4
N <sub>10</sub> = 1.5	



## ORIGINAL TEST REPORT

Akustikverkstan report 17-321-M7

## DATE OF REPORT

2017-12-08

