




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client: Götessons/ Gotessons
Object: HALF A HUT WITH FRONT SCREENS AND DOOR
Size [mm]: w = 1880 h = 2270 d = 970

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	2.6
125	2.7
250	5.2
500	6.5
1000	7.2
2000	8
4000	9.4
N ₁₀ = 1.5	



ORIGINAL TEST REPORT

Akustikverkstan report 17-321-M7

DATE OF REPORT

2017-12-08

