




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons		
Object:	HALF A HUT		
Size [mm]:	w = 1880	h = 2270	d = 900

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	2.4
125	2.4
250	5.5
500	6.9
1000	8.1
2000	8.8
4000	9.7
N₁₀ = 1.4	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-321-M5	2017-12-08

