




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons		
Object:	Hang Over		
Size [mm]:	w = 810	h = 690	d = 130

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.1
250	0.3
500	0.6
1000	0.8
2000	0.9
4000	1
N₁₀ = 16.7	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-321-M13	2017-12-08

