




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons, Akustikmiljö / Am Acoustics		
Object:	Honey 8 pcs		
Size [mm]:	w = 1950	h = 1560	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.2
125	0.5
250	1.2
500	2
1000	2.3
2000	2.3
4000	2
N₁₀ = 5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-321-M11	2017-12-08

