




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons		
Object:	THE HUT WITH FRONT SCREENS		
Size [mm]:	w = 1880	h = 2270	d = 1870

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	4.3
125	3.5
250	7.3
500	8.9
1000	10.2
2000	11.4
4000	12.9
N₁₀ = 1.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-321-M1	2017-12-08

