




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Götessons/ Gotessons		
<b>Object:</b>	THE HUT WITH FRONT SCREENS AND DOOR		
<b>Size [mm]:</b>	w = 1880	h = 2270	d = 1800

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	3.6
125	4.8
250	7.3
500	8.8
1000	9.7
2000	10.6
4000	11.9
<b>N<sub>10</sub> = 1.1</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 17-321-M2	2017-12-08

