




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons, Akustikmiljö / Am Acoustics		
Object:	Honey		
Size [mm]:	w = 600	h = 520	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.1
250	0.2
500	0.4
1000	0.4
2000	0.4
4000	0.3
N₁₀ = 33.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-321-M12	2017-12-04

