




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	dB Floor Screen		
<b>Size [mm]:</b>	w = 800	h = 1500	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.2
125	0.3
250	0.7
500	1.2
1000	1.5
2000	1.5
4000	1.6
<b>N<sub>10</sub> = 8.3</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan 17-360-M1	2018-01-23

