




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Decibel AB		
<b>Object:</b>	Chesterfield (6 pcs)		
<b>Size [mm]:</b>	w = 600	h = 600	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.6
250	1.6
500	2.6
1000	2.7
2000	2.5
4000	2.3
<b>N<sub>10</sub> = 4.3</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikversktan 18-051-M10	2018-06-12

