




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Hertz 6 pcs		
Size [mm]:	w = 1200	h = 1800	d = 60

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	1
250	2.2
500	2.8
1000	2.9
2000	2.6
4000	2.4
N₁₀ = 4.2	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverskan 18-051-M13	2018-10-22

