




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Decibel AB		
<b>Object:</b>	Hertz 6 pcs		
<b>Size [mm]:</b>	w = 1200	h = 1800	d = 60

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	1
250	2.2
500	2.8
1000	2.9
2000	2.6
4000	2.4
<b>N<sub>10</sub> = 4.2</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverskan 18-051-M13	2018-10-22

