




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Hertz 6 pcs		
Size [mm]:	w = 1200	h = 1800	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.6
250	1.5
500	2.6
1000	2.9
2000	2.5
4000	2.2
N₁₀ = 4.5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-051-M12	2018-10-22

