




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Decibel AB		
<b>Object:</b>	Hertz 6 pcs		
<b>Size [mm]:</b>	w = 1200	h = 1800	d = 80

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.3
125	1.6
250	2.4
500	3
1000	3.2
2000	2.8
4000	2.5
<b>N<sub>10</sub> = 4</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 18-051-M9	2018-10-22

