




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Hertz 6 pcs		
Size [mm]:	w = 1200	h = 1800	d = 80

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	1.6
250	2.4
500	3
1000	3.2
2000	2.8
4000	2.5
N₁₀ = 4	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-051-M9	2018-10-22

