




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Illusion (6 pcs)		
Size [mm]:	w = 1200	h = 1890	d = 120

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.7
250	1.5
500	2.3
1000	2.5
2000	2.7
4000	2.6
N₁₀ = 4.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-051-M11	2018-06-12

