




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

| | | | |
|-------------------|--------------------|----------|---------|
| Client: | Glimakra Of Sweden | | |
| Object: | Wannabetree No. 4 | | |
| Size [mm]: | w = 1070 | h = 1415 | d = 560 |

| Octave band (Hz) | Equivalent sound absorption area / unit (m ² Sabine) |
|------------------------------|---|
| 63 | 0.03 |
| 125 | 0.16 |
| 250 | 0.42 |
| 500 | 0.84 |
| 1000 | 1.52 |
| 2000 | 1.8 |
| 4000 | 1.75 |
| N₁₀ = 11.9 | |



| | |
|-----------------------------|---------------------|
| ORIGINAL TEST REPORT | DATE OF TEST |
| SP report 10188024 | 2013-11-04 |

