




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Glimakra Of Sweden		
Object:	Wannabetree No. 4		
Size [mm]:	w = 1070	h = 1415	d = 560

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.03
125	0.16
250	0.42
500	0.84
1000	1.52
2000	1.8
4000	1.75
N₁₀ = 11.9	



ORIGINAL TEST REPORT	DATE OF TEST
SP report 10188024	2013-11-04

