




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Glimakra Of Sweden		
<b>Object:</b>	Wannabetree No. 6		
<b>Size [mm]:</b>	w = 1235	h = 2085	d = 560

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.12
125	0.3
250	0.76
500	1.74
1000	2.93
2000	3.47
4000	3.46
<b>N<sub>10</sub> = 5.7</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
SP report 10188024	2013-11-04

