




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Aircone 10 pcs		
Size [mm]:	w = 928	h = 1206	d = 43

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.02
125	0.1
250	0.5
500	0.9
1000	0.9
2000	0.9
4000	0.8
N₁₀ = 12.5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 13-137-M7	2013-11-12

