




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Lily		
Size [mm]:	w = 900	h = 900	d = 10

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.2
250	0.4
500	0.7
1000	1
2000	1.3
4000	1.3
N₁₀ = 14.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-720-M12	2019-01-14

