




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Lily		
<b>Size [mm]:</b>	w = 900	h = 900	d = 10

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	0.2
250	0.4
500	0.7
1000	1
2000	1.3
4000	1.3
<b>N<sub>10</sub> = 14.3</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 18-720-M12	2019-01-14

