




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Airbloom 10 pcs		
Size [mm]:	w = 912	h = 2325	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.05
250	0.15
500	0.3
1000	0.5
2000	0.6
4000	0.7
N₁₀ = 33.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-094-M12	2017-05-10

