




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Airleaf 10 pcs		
<b>Size [mm]:</b>	w = 900	h = 1300	d = 20

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	0
250	0
500	0.19
1000	0.43
2000	0.89
4000	1.14
<b>N<sub>10</sub> = 52.6</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
KTH-MWL LW201609_R3	2016-09-23

