




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Airleaf 10 pcs		
Size [mm]:	w = 900	h = 1300	d = 20

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0
250	0
500	0.19
1000	0.43
2000	0.89
4000	1.14
N₁₀ = 52.6	



ORIGINAL TEST REPORT	DATE OF REPORT
KTH-MWL LW201609_R3	2016-09-23

